



## RCU Pressure Transducers

### OVERVIEW

Remote Condensing units may be equipped with transducers that utilize Schrader depressor pressure connections, non-typical CPC (EMC) 1/8" male pipe thread (MPT) pressure connections

#### Refrigeration Contractor:

- When replacing the suction or discharge transducers on condensing units contact EMC
- Use Part numbers;
  - EMC/GP(0-200G)-U-P-4.5V-000-000 Suction pressure Schrader depressor
  - EMC/GP(0-500S)-U-P-4.5V-000-000 Discharge pressure Schrader depressor
  - EMC/800-2200 Suction pressure CPC type 1/8 MPT
  - EMC/800-2500 Discharge pressure CPC type 1/8 MPT

#### Other considerations:

- Transducers for remote condensing units are considered non-critical/non-emergency
- CM WO only, if FMOC or others are issuing EM WO's, please decline the EM request and direct to Target Refrigeration Operations Technical Lead, or FMOC Lead Specialist Refrigeration