

4.1 Leak Checks

Submitted by: caleb@linq.io

Leak Check Process & Areas		
Shut down rack to allow pressure to build on low side. Do not leave off more than 1 hour at a time, make sure suppression is in place and the Store Manager is aware that equipment is off	X	
Leak check all rack components		
Leak check condenser		
Leak check cases		
Leak check walk ins		
Leak check pits (if applicable)		