

PREVENTIVE MAINTENANCE FOR 360'S

DATE \_\_\_\_\_ STORE \_\_\_\_\_ VOLTAGE \_\_\_\_\_

MODEL \_\_\_\_\_

SERIAL \_\_\_\_\_

- \*\*MAKE APPOINTMENT WITH STORE\*\*
- \*\*AS CASE SHOULD BE EMPTY, REMOVE THE BOTTOM PANELS\*\*
- \*\*REMOVE THE TOWER, TAKE OUTSIDE TO BE CLEANED\*\*
- \*\*REMOVE MOTORS, AND WASH OUT EVERY EVAPORATOR COIL\*\*
- \*\*CLEAN FAN BLADES, CHECK MOTORS FOR PROPER OPERATION\*\*
- \*\*VERIFY SHROUDS ARE INPLACE AND CLEAN\*\*
- \*\*WASH OUT DRAIN, PEE-TRAP, AND CHECK CONDITION\*\*
- \*\*CHECK DRAIN FOR ANY CRACKS, RUST-OUTS, LACK OF SILICONE\*\*
- \*\*CHECK ALL WIRING, VERIFY NO CUT WIRES, LOOSE WIRE CONNECTIONS\*\*
- \*\*CHECK FOR ANY DAMAGE TO THE EVAPORATORS, VERIFY NO LEAKS\*\*
- \*\*CHECK COPPER LINES, VERIFY THEY ARE CLEAN FROM OIL AND SECURE\*\*
- \*\*WASH OUT CONDENSER COIL\*\*
- \*\*CHECK CONDITION OF THE CFM, AND VERIFY THAT IT IS CLEAN AND BALANCED\*\*
- \*\*CHECK ELECTRICAL IN THE CONDENSER, VERIFY CONTACTS, RELAYS, TIMERS ARE CLEAN AND OPERATING GOOD\*\*
- \*\*AFTER UNIT IS RUNNING, RECORD THE FOLLOWING\*\*

COMPRESSOR AMPS \_\_\_\_\_ RATED \_\_\_\_\_

CFM AMPS \_\_\_\_\_, \_\_\_\_\_ RATED \_\_\_\_\_

EVAPORATOR MOTOR AMPS RATED \_\_\_\_\_

\_\_\_\_\_

SUCTION PRESSURE \_\_\_\_\_ DISCHARGE PRESSURE \_\_\_\_\_ S.H. \_\_\_\_\_ SUB-COOLING \_\_\_\_\_

TEMP OF CASE \_\_\_\_\_

NOTE\*\* WHILE CHECKING FANS AND COMPRESSORS, PLEASE NOTE ANY NOISY COMPONENTS.

PLEASE LIST ANY OTHER PROBLEMS OBSERVED, SUCH AS CONDITION OF COILS, CONDITION OF UNITS, ROTT-OUTS, NON-CONDENSABLES, BEARING ON FANS and MOTORS.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

NAME OF SERVICE TECHNICIANS

\_\_\_\_\_