

## 2.1 Case PM

Submitted by: caleb@linq.io

Case Checks		
Confirmation Email	X	
Management Email	X	
Verify case has proper airflow (replace faulty fan motors)		
Verify all cases on the circuit are within $\pm 2^\circ$ of target setpoint		
Confirm return air grill is unobstructed by price tags, wire racks, product, etc.		

Miscellaneous Checks (Case)		
Mirrors are removed if there are 5 rows of shelves (if present, get with store manager to have removed)		
Visually check that correct shelving is in place (stores can order shelving through GNFR process)		
Verify shelf extensions are in place on all angled shelves		
Verify cases are properly stocked and load limits are not exceeded		
Recalibrate thermometer, replace if necessary		
Note any scope item submissions and fill out Scope Forms at this time		