Technician:	Make a copy and leave visible in motor room and send
Date:	a copy to Miller Construction Services, Inc. Email to
Warehouse:	Service@millerconstructionservices.com

## Manager

Signature				
ITEM	PREVENTATIVE MAINTENANCE	Complete Yes/No	Extra Work Required	Notes
1	Check in with Warehouse Manager	-	1 ' 1	
2	Inspect and tighten all elecrical connections on racks and check			
	compressor contactors for wear			
_	Check all oil safety contacts, high/low pressure controls and other			
3	compressor controls for proper settings. Verify that they function			
	properly   Check all compressors for signs of short cycling. Note any		+	
4	compressors that are short cycling.			
	compressors that are short eyoning.		+	
_	Check and record suction set points:			
5				
	Rack C:   Rack D:			
	Check and record power supply voltage for each rack:			
6	Rack A L1-L2: L2-3: L1-L3:			
	Rack B:L1-L2 L2-3: L1-L3:			
	Rack C:L1-L2 L2-3:			
7	Verify phase monitor settings if present			
8	Verify proper heat reclaim operation and check for leaks on tank.			
	Heat reclaim#1 temp out Heat reclaim#2 temp out Check compressor oil levels.		+	
	Rack A oil resevoir level: Rack B oil resevoir level			
9	Rack A oil condition & color Rack B oil condition			
	& color			
	Check and record refrigerant levels:			
10	Rack A:R Level:   Rack B:R- Level:			
10				
	Rack C:R			
	Verify that all schrader valves have caps in place and that all service			
11	valves have caps on valve stems. NO PLASTIC CAPS on Schrader			
	valves.			
	Inspect all hydrozorbs, vibration eliminators, and super hoses. Note if any could be refrigerant leak issues in the future and if so, write up to			
12	be replaced. All super hoses are to be replaced using the braided			
	hose (not the rubber)			
	Check and record color of moisture indicator on each rack:		+ +	
13	Rack A: Rack B:			
	Rack C: Rack D:			
14	Check crankcase heater operation if applicable.			

ITEM	PREVENTATIVE MAINTENANCE	Complete Yes/No	Extra Work Required	Notes
15	Check transducer calibration. If less than 10psi off, then calibrate transducer. If more than 10psi off, mark it for replacement on T & M.			
16	Check head fan motor operation. Clean fan guards and oil coolers.			
17	Check condenser fan contactors			
18	Inspect condensers and verify that all fans function. Check condenser settings in controller.			
19	Check settings on split condenser and verify operation.			
20	Check for proper air flow through condensers.			
21	On systems, check and record condenser subcooling:  Rack A Rack B: Rack C Rack D:  Check condenser fans, fan blades, brackets and where it attaches to the frame for vibration and stress cracks. Check the first two banks			
	on each condenser.			
23	Check all systems for floodback and note.			
24	Inspect cases for proper airflow and case operartion.			
25	Brush off all case return air grills as needed.			
26	Inspect trim on all cases. Secure loose pieces and eliminate hazardous and sharp edges. Make sure there are no safety issues for customers or employees.			
27	Check all glass doors to ensure they close properly. Also check gaskets.			
28	Check anti-sweat controls, if applicable for proper operation.			
29	Clean radiators on pumps (if applicable)			
30	Inspect walk in cooler/freezer evaporator coils and fan guards for dirt and ice. Check that all fans are operating			
31	Confirm All alarm settings and temperature settings in refrigeration controller are to Costco specification. Note any adjustments or changes and notify MCS.			
32	Check all circuit temperatures in controller. Verify that all systems are maintaining proper temperatures.			
33	Check alarm logs. Identify recurring alarms that need attention.			
34	Test and verify that local alarm lights and horn function properly.  Also test and verify that refrigeration alarm connection is hooked up by simulating a rack alarm and confirming warehouse receives notification of that alarm from the alarm company.			
35	Check entire warehouse for leaks with electronic leak detector, including rooftop condensers. This needs to be noted on a separate service ticket with the hours spent leak checking			

ITEM	PREVENTATIVE MAINTENANCE	Complete Yes/No	Extra Work Required	Notes
36	Check refrigerant piping clamps and hangers. Tighten loose connections.			
37	Check all refrigeration room doors for proper sealing and operation (POS boxes, Prep rooms, Coolers, Shop-In's, etc.)			
38	Check all lighting in Cases, Prep rooms, POS boxes, Coolers, Shop-Ins, etc. Note those that need replacement.			
39	Visually check refrigerant piping insulation for missing sections or splits.			
40	Check operation of machine room ventilation room. Verify that exhaust fan/damper works.			
41	Clean compressor room. Empty any garbage cans. Remove oil from racks, compressors, frames, rack pans and lines.			
42	Inspect all self contained refrigerated units in store for proper operation and clean condensers.			
43	If Required: Inspect Cooling Tower (If Tower requires cleaning, then perform cleaning on T & M). Check overall function of Tower. Grease or lube bearings, check belts.			
44	Check HCR Air Door/s for proper function and calibration using ribbon test. Also check belts for wear.			
45	Leave a copy of this inspection report in machine room file box.			
46	Test Freon Leak Detector(s) to confirm proper function and that they properly communicate with Micro Thermo if present or the rack controller.			
47	Check operation of all exhaust fans in pizza, chicken, bakery, meat, and deli prep areas.			
48	Clean condensers on Ice O Matic ice machine in meat area.			
49	Clean Meat Department ice machines using nickel safe cleaner and sanitizer.			
50	Complete electrical check on floral cases (drains cleaned, pan and heater checked for corrosion, float for operation). If new style floral case (on a pump) change out filters for condensers.			
51	Complete Alarm form and signature by warehouse manager.			
52	If Glycol System is Present			
53	Check Pump Controls to insure proper operation (low temp thermostat, Pump differential pressure switches, system relief valves), note any issues			
54	Verify the pump cycling sequence is operating correctly		<del>                                     </del>	
55	Check the low temperature (freeze stat) turns off the liquid line solenoid valve(s)			
56	If pump bearings are not sealed (grease if needed)		+ +	
57	Visually inspect pumps/piping/exchangers for signs of leaks, note any leaks for repair.			

ITEM	PREVENTATIVE MAINTENANCE	Complete Yes/No	Extra Work Required		Notes
58	Leak check glycol system for refrigerant leaks. At valve station on top of Meat/Dairy Cooler, crack a valve to check for refrigerant being present in glycol system. If noticed, get samplea and notify MCS immediately.				
59	Check Glycol concentration percentage to make sure it is 35%-Check Glycol Temperature with refractometer. Take a picture and send to MCS.				
60	Check for visible Glycol level in overflow tank				
61	Wipe down pan for pump station				
62	Check the pressure differential across Coalescing Oil Separators. Need to check and record pressure difference and replace filter pressure difference if 5 psi or greater.				
63	Cleaned motor room photos sent to MCS. Please email photos to Service@millerconstructionservices.com				
64	Check electrical panels on Refrigeration mezzanine or Electrical mezzanine and ensure they are properly secured to the wall.				
		<u> </u>			
	Items that Require Additional Work		Reason for Follow-Up  uct Refrigerant Energy Maintenance		
1		Product	rteingerant	Lifelgy	Mannenance
2					
3					
4					
5					
6					
7					
8					
9					
10					